

FIRE EXTINGUISHER WALL BRACKET HEIGHTS

- Max - 1200mm from floor to top of extinguisher handle
- Min - 100mm from floor to bottom of the extinguisher

LOCATION AND DISPLAY OF SIGNS

NOTE: Use double sided tape or liquid nails to mount the signs - DO NOT use petroleum-based glues, as it will damage the signs

Location Signs

- Min - 2000mm from floor to the bottom of the sign and located directly above fire extinguisher bracket
- Must be visible from 20 metres away in all directions and not covered by boxes etc

Identification Signs

- Must be placed directly above the fire extinguisher - no specific height required

